



Representing the best in electrical engineering and building services



FIRE ALARM SERVICING CERTIFICATE

As recommended in Annex G of British Standard BS5839-1:2013 **FS 187218**

© Copyright The Electrical Contractors' Association

This certificate is not valid if the number has been defaced or altered.

Certificate of servicing for the fire alarm system at:

Address: **Thingamajigz Unit 5/6 Millenium Court, Furness Dr, Poulton Business Park, Poulton-le-Fylde, FY6 8JS**

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the servicing of the fire alarm system, particulars of which are set out below, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS5839-1:2013 quarterly inspection of vented batteries/periodic inspection and test/inspection and test over a '6 month period (delete as applicable), except for the variations, if any, stated in this certificate.

Name (in block letters): **J. Southworth**

Position: **Principal Duty Holder E.C.A. Member**

Signature: Date: **26/10/2018**

For and on behalf of: **Premier Electrical**

Address: **58 Fleetwood Road
Poulton Le Fylde**

Postcode: **FY6 7NL**

The extent of liability of the signatory is limited to the system described below.

Extent of system covered by this certificate

Whole of System

Variations from the recommendations of Clause 45 of BS5839-1:2013 for periodic or annual inspection and test (as applicable):

None

Relevant details of the work carried out and faults identified have been entered in the system log book.

During the past 12 months, false alarms have occurred.

The above number of false alarms equates to false alarms per 100 automatic fire detectors per annum (for Category M systems enter "Not applicable").

The following work/action is considered necessary: